



# New Mexico Regulation and Licensing Department

## CONSTRUCTION INDUSTRIES DIVISION

P.O. Box 25101 ▪ Santa Fe, NM 87504 ▪ Ph. (505) 476-4675 ▪ Fax (505) 476-4685  
 5500 San Antonio Dr. NE ▪ Albuquerque, NM 87109 ▪ Ph. (505) 222-9800 ▪ Fax (505) 765-5670  
 505 S. Main St., Suite 103 ▪ Las Cruces, NM 88004 ▪ Ph (575) 524-6320 ▪ Fax (575) 524-6319  
[www.rld.state.nm.us/construction](http://www.rld.state.nm.us/construction)

### STATE OF NEW MEXICO DUCT SEALING VISUAL INSPECTION CHECKLIST

Home Address: \_\_\_\_\_ City: \_\_\_\_\_ State: NM

Duct Sealing	Inspection Guidelines	Corrections Needed	Builder Verified	Rater Verified	N/A
Overall Sealing	Requirements: Ducts, air handlers and filter boxes shall be sealed. Joints and seams shall comply with the New Mexico Mechanical Code, as applicable				
	All Climate Zones:				
	1.1 All Duct work connections performed per International Residential Code as applicable	Y/N	Y/N	Y/N	Y/N
	1.2 All Flexible Ductwork (elbows, wyes) is sealed per International Residential Code as applicable	Y/N	Y/N	Y/N	Y/N
	1.3 Air handler to ductwork is sealed per International Residential Code as applicable	Y/N	Y/N	Y/N	Y/N
1.4 No Building cavities have been used as ducts or plenums	Y/N	Y/N	Y/N	Y/N	
Inspected by: (Check one) <input type="checkbox"/> Energy Rater <b>OR</b> <input type="checkbox"/> Builder <b>OR</b> <input type="checkbox"/> Code Official    Inspection Date: ____/____/____					
Company/Government Entity Name: _____					
Signature: _____ Printed Name _____					